

# ***Buda Fire Department***

*Hays County Emergency Services District # 8*

P.O. Box 1159, Buda, TX 78610

Administration: (512) 295-2232

Fax: (512) 295-2848



---

## Construction Office Permit

All Construction Offices moved on to the building site shall be required to obtain an operational permit issued by the Fire Marshal's Office. Provisions to obtain a permit:

1. An approved address posted at site entrance
2. Security Gates will be required to have a Knox Padlock attached. (supplied by FD)
3. Minimum of (1) 2A fire extinguisher per office building and (1) 2A per each construction shed(s).
4. Dumpsters and containers more than 40.5 cubic feet shall not be within 5 feet of combustible walls, openings or under eave lines and less than 10 feet of property lines.
5. Electrical service to office building shall be buried or > 8' high
6. Flammable and Combustible liquids in excess of 5 gallons shall not be stored inside of office building. All flammable and combustible liquids shall be stored in metal safety cans.
7. Site and building access shall be maintained at all times.
8. Above Ground Storage Tanks/Petroleum Storage Tanks - Contact Fire Marshal's Office prior to installing storage tank for requirements.

The permit application can be found at ([www.budafire.org](http://www.budafire.org)) (Code Enforcement) then scroll to bottom of page. Permit Fee of \$100 will be assessed with check made out to Buda Fire Department.