

Buda Fire Department

Hays County Emergency Services District # 8

P.O. Box 1159, Buda, TX 78610

Administration: (512) 295-2232

Fax: (512) 295-2848



Buda Fire Department Fire Prevention Division Tank Installation Permit Requirements

General Requirements:

All Petroleum Storage Tanks (PST) must be installed in accordance with the International Fire Code (IFC) - 2006 Chapters 27 and 34, NFPA 30 - 2003, and TAC Title 30 Part 1 Chapter 334.

_____ Permit Application

_____ Copy of License : Contractor License (TCEQ)

Supervisor License - Class B (TCEQ)

License is not required for tanks installed as an integral component of another piece of equipment (i.e. generators)

_____ Submittal Packet (1 copy)

- Location of job site (address)
- Site plan of tanks to be installed
- Detailed plans with dimensions including: location and size of sampling wells, location and description of vent piping, type and thickness of cover of tanks (dirt, asphalt, concrete).
- Cut sheets of all devices attached to the tank(s)
- Tank description: capacity, construction (single wall, etc.), material (steel, etc.), release detection method.
- Letter from Texas Commission on Environmental Quality (TCEQ) acknowledging receipt of the UST Construction Notification Form.

Construction notification is not required for ASTs less than 1,100 gallons water capacity unless associated with a retail fuel facility.

_____ Inspection Requirements:

- Tank tightness test
- Piping pressure test

Plans review process may take up to 10 working days. Incomplete plans may require that the plans be resubmitted. Inspections are required and should be called in at least 48 hours prior to requested inspection times. A re-inspection fee of \$50 will be assessed on systems that are not in complete compliance with all applicable codes. All devices will be tested in an approved manner.