

Buda Fire Department

Hays County Emergency Services District # 8

P.O. Box 1159, Buda, TX 78610

Administration: (512) 295-2232

Fax: (512) 295-2848



Buda Fire Department Fire Prevention Division Fire Sprinkler Plan Submittal Requirements

Fire Sprinkler Systems installed in the Buda Fire Department/ESD #8 fire district shall meet all the requirements of the 2006 International Fire Code and Building Code, local amendments, as well as all applicable NFPA Standards. All final systems testing and inspections will be witnessed by the Buda Fire Department Fire Prevention Division. The following is check list of information that should be used as an aid and is not intended to cover every code requirement.

 Permit Application

 Copy of current license issued by the State of Texas Fire Marshal (1 Copy)

- RME
- Contractor/Company
- Installers

 Submittal Packet (1 Copy)

- System Design Description
- Edition of NFPA 13, 13R, 13D
- Building information to include hazard type and construction type
- Manufacturer's Approved Product Information Sheets of Listed Devices and Equipment
- Hydraulic Calculations
- Friction Loss Calculations
- Piping and fittings specifications
- Riser Diagram and specifications
- List of materials

 1/8 Scaled Plans (3 copies)

- Site Plan with hydrant locations and distance and main sizes
- Legend with appropriate sprinkler head specification
- North Arrow
- Floor Plans Drawn that are free of extraneous information
- All Rooms Labeled for Intended Use to include dimensions
- Hanger Detail
- Full Height cross section of each floor
- Location of partitions and fire walls
- Total number of heads for each riser per floor
- Location of risers
- Location of all piping and sizes
- Location of 2 ½"-Siamese FDC
- Location of alarm bell

- Capacity dry pipe or anti-freeze systems
- All labeling and signage posted in accordance with NFPA 13,13R,13D
- System Designers Stamp with Wet Signature

_____ **Modification Permit (up to 20 heads)**

- Permit Application
- Copy of Licenses
- Plans 1/8 scale, 3 copies, stamped and wet signed
- Legend showing existing, relocated, additional or plugged heads or lines
- Cut sheets for each new device or piece of equipment
- Indicate hazard type for area served

_____ **Underground Requirements (Fire Line)**

- Permit application
- Copy of License certifying such work
- Plans-1/8 scale, 3 copies, stamped and wet signed
- Foot print of facility
- Nearest hydrant
- Fire line detail (depth and pipe sizes)
- Thrust blocking
- Location of pit or vault
- FDC and Riser
- Flow Test data
- Cut sheets for all material used

_____ **Required Inspections**

- Underground Visual (all joints and connections)
- Underground Hydro (Minimum 200 PSI- 2hrs)
- Above Ceiling Visual (prior to covering any pipe)
- Above Ceiling Hydro (Minimum 200 PSI- 2hrs)
- Final Acceptance

Plans review process may take up to 10 working days. Incomplete plans may require that the plans be resubmitted. System acceptance inspections are required and should be called in at least 48 hours prior to requested inspection times. A re-inspection fee of \$50 will be assessed on systems not in complete compliance with all applicable codes. All devices will be tested in an approved manner.

INSTALLATION/ MODIFICATION PERMIT AND AN APPROVED SET OF PLANS SHALL REMAIN

AT THE JOB SITE AND PROVIDED TO INSPECTORS WHEN REQUESTED.

Date